



Ministry
of the
Environment

Ministère
de
l'Environnement

CERTIFICATE OF APPROVAL
AIR
NUMBER 4769-5R3KWG

Her Majesty the Queen in Right of Ontario as represented by the Minister of Natural Resources
PO Box 7000 Stn Main
Peterborough, Ontario
K9J 8M5

Site Location: Blue Lake Provincial Park
P.O. Box 264, Blue Lake Road
Vermilion Unorganized Township, District of Kenora
P0V 2V0

You have applied in accordance with Section 9 of the Environmental Protection Act for approval of:

- one (1) standby propane generator set, having a rating of 85 kilowatts, to provide power for the provincial park during emergency situations;

all in accordance with the Application for Approval (Air) dated September 12, 2002, and all supporting documentation and information, signed by Joachim Kolodziej, P.Eng. (Coordinator, Environmental Design), Ministry of Natural Resources.

For the purpose of this Certificate of Approval and the terms and conditions specified below, the following definitions apply:

- (1) "Act" means the *Environmental Protection Act*;
- (2) "Certificate" means this Certificate of Approval issued in accordance with Section 9 of the Act;
- (3) "Equipment" means the propane generator set described in the Owner's application, this Certificate and in the supporting documentation submitted with the application, to the extent approved by this Certificate;
- (4) "Manual" means a document or a set of documents that provide written instructions to staff of the Owner;
- (5) "Ministry" means the Ontario Ministry of the Environment; and
- (6) "Owner" means Ministry of Natural Resources, and includes its successors and assignees.

You are hereby notified that this approval is issued to you subject to the terms and conditions outlined below:

TERMS AND CONDITIONS

GENERAL

1. Except as otherwise provided by these Conditions, the Owner shall design, build, install, operate and maintain the Equipment in accordance with the description given in this Certificate, application for approval of the Equipment and the submitted supporting documents and plans and specifications as listed in this Certificate.
2. Where there is a conflict between a provision of any submitted document referred to in this Certificate and the

CONTENT COPY OF ORIGINAL

Conditions of this Certificate, the Conditions in this Certificate shall take precedence, and where there is a conflict between the listed submitted documents, the document bearing the most recent date shall prevail.

OPERATION AND MAINTENANCE

3. The Owner shall ensure that the Equipment is properly operated and maintained at all times. The Owner shall:

(1) prepare, not later than three (3) months after the date of this Certificate, and update, as necessary, a Manual outlining the operating procedures and a maintenance program for the Equipment, including:

- (a) routine operating and maintenance procedures in accordance with good engineering practices and as recommended by the Equipment suppliers;
- (b) emergency procedures;
- (c) procedures for any record keeping activities relating to operation and maintenance of the Equipment;
- (d) all appropriate measures to minimize noise and odorous emissions from all potential sources;

(2) implement the recommendations of the Manual; and

(3) retain, for a minimum of two (2) years from the date of their creation, all records on the maintenance, repair and inspection of the Equipment, and make these records available for review by staff of the Ministry upon request.

The reasons for the imposition of these terms and conditions are as follows:

1. Condition Nos. 1 and 2 are imposed to ensure that the Equipment is built and operated in the manner in which it was described for review and upon which approval was granted. These conditions are also included to emphasize the precedence of Conditions in the Certificate and the practice that the Approval is based on the most current document, if several conflicting documents are submitted for review.

2. Condition No. 3 is included to emphasize that the Equipment must be maintained and operated according to a procedure that will result in compliance with the Act, the regulations and this Certificate. In addition the Owner is required to keep records and provide information to staff of the Ministry so that compliance with the Act, the regulations and this Certificate can be verified.

In accordance with Section 139 of the Environmental Protection Act, R.S.O. 1990, Chapter E-19, as amended, you may by written notice served upon me and the Environmental Review Tribunal within 15 days after receipt of this Notice, require a hearing by the Tribunal. Section 142 of the Environmental Protection Act, provides that the Notice requiring the hearing shall state:

- 1. The portions of the approval or each term or condition in the approval in respect of which the hearing is required, and;
- 2. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

The Notice should also include:

- 3. The name of the appellant;
- 4. The address of the appellant;
- 5. The Certificate of Approval number;
- 6. The date of the Certificate of Approval;
- 7. The name of the Director;
- 8. The municipality within which the works are located;

CONTENT COPY OF ORIGINAL

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:

The Secretary*
Environmental Review Tribunal
2300 Yonge St., 12th Floor
P.O. Box 2382
Toronto, Ontario
M4P 1E4

AND

The Director
Section 9, *Environmental Protection Act*
Ministry of Environment and Energy
2 St. Clair Avenue West, Floor 12A
Toronto, Ontario
M4V 1L5

*** Further information on the Environmental Review Tribunal's requirements for an appeal can be obtained directly from the Tribunal at:
Tel: (416) 314-4600, Fax: (416) 314-4506 or www.ert.gov.on.ca**

The above noted works are approved under Section 9 of the Environmental Protection Act.

DATED AT TORONTO this 4th day of September, 2003

Aziz Ahmed, P.Eng.
Director
Section 9, *Environmental Protection Act*

AA/
c: District Manager, MOE Thunder Bay - District
Saibal Basu, Stantec Consulting Ltd.